



CERTIFICATE

The company :

Céra-Labo
ZI de la Montagne de l'Aspre
30150 Roquemaure
France

Has carried out particle cleanliness tests in accordance with standards ISO 14644-1 and US FS 209E

For the company :

Armstrong Building Products
67, rue de Salins
B.P. 89
25302 Pontarlier Cedex
France

The ceiling tile :

Bioguard Acoustic

has been tested for particle sizes 0,2 ; 0,3 ; 0,5 ; 1 and 5 μm ,
under a Micro-biological Safety Cabinet, calibrated to ISO 5.

The tests have determined the following particle classes :

ISO 5, according to standard ISO 14644-1

&

Classe 100, according to standard US FS 209 E.

The results of these tests correspond to report nr 6 01 003 – Armstrong Bioguard Acoustic / 1 Ver. 0
dated February 17th, 2006.

The Managing Director

Siège social / ZI Montagne de l'Aspre – 30150 ROQUEMAURE

Tél. 04.66.90.09.56 – Fax. 04.66.90.09.57

Internet : <http://ceralabo.com> E-mail. ceralabo@ceralabo.com

RCS Nîmes B 428 198 337 sîret / 428 198 337 00050 intracom / R 644 281 98 337 S.A.R.L au capital de 50000 Euros