



CERTIFICATE

The company : **Céra-Labo**
ZI de la Montagne de l'Aspre
30150 Roquemaure - France

Has carried out particle cleanliness tests in accordance with standards ISO 14644-1:1999 and US FS 209E

For the company : **Armstrong Building Products**
67, rue de Salins
B.P. 89
25302 PONTARLIER CEDEX - France

The ceiling tile :

BIOGUARD PLAIN

has been tested for particle sizes 0,2 ; 0,3 ; 0,5 ; 1 and 5 μm ,
under a Micro-biological Safety Cabinet, calibrated to ISO 5.

The tests have determined the following particle classes :

ISO 5, according to standard ISO 14644-1: 1999

&

Classe 100, according to standard US FS 209 E.

The results of these tests correspond to report nr 6 01 003 – Armstrong Bioguard Plain / 1 Ver. 0 dated March 18th, 2006.

The Managing Director