



CERTIFICATE

The company: **Céra-Labo**
ZI de la Montagne de l'Aspre
30150 Roquemaure - France

Has carried out particle cleanliness tests in accordance with standards ISO 14644-1:1999

For the company: **Armstrong Building Products**
67, rue de Salins
B.P. 89
25302 PONTARLIER CEDEX - France

The face of ceiling tile:

ALPINA

has been tested for particle sizes 0,2 ; 0,3 ; 0,5 and 5 µm,
Under a Micro-biological Safety Cabinet, calibrated to ISO 5.

The tests have determined on Alpina finish with different substrates the following particle classes:

ISO 5, according to standard ISO 14644-1: 1999

&

ZONE 4, according to standard NF S 90-351.

The results of these tests correspond to report nr 11 02 013 – Armstrong Alpina / 1 Ver.0 dated February 28TH, 2011

The Managing Director