

	F TECH 021
	Version n°4 – 13.01.14 - Page 1 sur 1
	CERTIFICAT



CERTIFICATE

The company: **Céra-Labo**
ZAC de Tésan – N°10
Impasse des Carignans
30126 Saint Laurent des Arbres - France

Has carried out particle cleanliness tests in accordance with standards ISO 14644-1:1999

For the company: **Armstrong Building Products**
67, rue de Salins
B.P. 89
25302 PONTARLIER CEDEX - France

The ceiling tile:

ULTIMA +

has been tested for particle sizes 0,2 ; 0,3 ; 0,5 ; 1 and 5 µm,
under a Micro-biological Safety Cabinet, calibrated to ISO 5.

The tests have determined the following particle classes:

ISO 5, according to standard ISO 14644-1: 1999

&

ZONE 4, according to standard NF S 90-351.

The results of these tests correspond to report nr 14 01 014 – Armstrong Ultima + / 1 Ver.1 dated May 22th, 2014.

The Managing Director